



Public Health
Prevent. Promote. Protect.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
ENVIRONMENTAL HEALTH PROGRAM

155 North First Avenue, MS 5, Suite 170
Hillsboro, OR 97124

Telephone: (503) 846-8722 ♦ Fax: (503) 846-3705

www.co.washington.or.us/foodsafety

Restaurant Re-Opening Checklist

The permit holder should ensure that all items on this checklist are completed:

Physical Facility

- Electricity is available throughout facility
- If applicable, natural gas is available to facility
- All plumbing is operating properly
- There is no visible damage or incomplete repairs, all gaps and holes are sealed
- Floors, walls, and ceiling are clean
- Lights are operational and at proper brightness
- Cold and hot water is available throughout the facility
- Hot water is available at a minimum of 100°F at every hand sink
- Hot water is available at a minimum of 110°F at the 3-compartment sink (if applicable)

Facility Operation

- All potentially contaminated food is discarded
- All kitchenware and equipment are properly washed, rinsed, sanitized, and air dried
- Dishwasher/glasswasher is operating properly
- All dishware and utensils are properly washed, rinsed, sanitized, and air dried
- Cold holding units are holding at or below 41°F
- Freezer units are holding at an acceptable freezing temperature (ideally below 0°F)
- All unit thermometers are working properly
- Hot holding units are holding at or above 135°F
- Hood ventilation system is operating properly
- Hand sinks and restrooms are stocked and operational

Operation Readiness

- Sanitizer buckets are set up at proper concentration
- Thermometers are calibrated
- Pest control records are available
- Air curtains are operating properly
- Person in Charge is available and knowledgeable
- All food handlers have current Food Handler Cards
- All food is labeled and dated as required

__ - __ - ____ / __ : __ AM / PM

Date / Time Closed (Circle One)

__ - __ - ____ / __ : __ AM / PM

Date / Time Re-Opened (Circle One)

34 _____
Facility Number

Name of Facility

Person in Charge