Public Swimming Pool Daily Record Sheet

Date: _____ **Name of Pool:** _____ **Owner:** _____ **Operator:** _____

31	30	29	28	27	26	25	24	23	22	21	20	19	18	17	16	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	**Day of the Month**
																															Main Drain
																															Gates and Doors
																															Safety Equipment
																															Clarity
																															pH
																															Combined Chlorine

Daily Pre-Opening Tests

Time Checked	**Free Chlorine** (ppm) • **Outdoor:** o Non-stabilized (hourly) o Stabilized (every 4 hours) • **Indoor:** (every 4 hours)

																															Total Alkalinity (weekly)
																															Calcium Hardness (weekly)
																															Cyanuric Acid (monthly)
																															Flow Rate (GPM)
																															Backwashed – Clean Filters
																															Soda Ash or Acid Added - specify
																															Super-Chlorinated or Oxidized
																															Pool Temperature

Water Quality Parameters – OAR 333-60-200

	MINIMUM	IDEAL	MAXIMUM
Free Chlorine	0.8 ppm	1-3.0 ppm	5.0 ppm
Combined Chlorine	0 ppm	0 ppm	0.5 ppm
Bromine	3.0 ppm	3.0-5.0 ppm	8.0 ppm
pH	7.2	7.4-7.6	7.6
Total Alkalinity	80 ppm	100-125 ppm	200 ppm
Cyanuric Acid	0 ppm	30 ppm	150 ppm
Calcium Hardness	175 ppm	250 ppm	---

POOL CLOSURE: _____

_____

_____

_____

OTHER INFORMATION: _____

_____

_____

_____